

UPPER CHICHESTER TOWNSHIP

OFFICE of the FIRE MARSHAL

PO. BOX 2187 Upper Chichester, PA. 19061 Phone : 610 - 842 - 8455 Fax : 610 - 485 - 8346

FIRE ALARM REQUIREMENTS

Fire alarm and detection systems shall be designed and installed in accordance with the following codes which are enforced in the Township of Upper Chichester.

- 2009 International Building Code
- 2009 International Fire Code
- 2009 International Mechanical Code
- NFPA 72 (National Fire Code) 2007 Edition

In accordance with NFPA 72, installation personnel will be qualified or shall be supervised by persons who are qualified in the installation, inspecting and testing of fire alarm systems.

- (1) Personnel who factory trained and certified for fire alarm installation of the specific type and brand of system being installed.
- (2) Personnel who are certified by a nationally recognized fire alarm certification organization (i.e. NICET) acceptable to Upper Chichester Township Fire Marshal and or Inspections Department.
- (3) Personnel who factory trained and certified for fire alarm service of the specific type and brand of system being installed.
- (4) Personnel who are employed and qualified by an organization listed by a nationally recognized for the serving of fire alarm systems (Underwriters Laboratories or Factory Mutual).

Page # 2 must be completed.

**EVIDENCE OF QUALIFICATIONS OR CERTIFICATIONS SHALL BE
PROVIDED UPON REQUEST BY THE FIRE MARSHAL OR INSPECTORS**

AFFIDAVIT OF TRAINING AND EXPERIENCE

I, _____ represent that I am qualified to install and/or service
fire alarm systems because I am :

A factory trained and certified individual

Fire Alarm certified by a nationally recognized fire alarm certification organization
(i.e. NICET)

An employed and qualified employee of an organization listed by a national testing
laboratory for the servicing of the fire alarm systems.

Please Attach Supporting Documentation

Signature : _____ Date :

Company :

Address :

Phone # : _____ Fax: